

Appliance Inspection & Test Record

Customer:

Am Water Services

Location: VAN WR75 ODL

Ant Anck

Engineer:

Richard Conwell

Test Date:

3/5/26

Retest Date: 3/11/26

Test Instrument: *E299H+ FL25*

Serial Number: W8441661

Page:

1

of

1

[illegible]

¹ Measured value should not exceed $(0.1 + R) \Omega$

(X) - Fail

(N/C) - Not Checked

(N/A) - Not Applicable

² Measured value should not be less than 1.0M Ω for Class I & 2.0M Ω for Class II